RCA Transmitting Tube Operating Considerations

The following operating considerations for RCA transmitting tubes are intended for use with the data sheets on individual tube types given in the Handbook. Operating considerations unique to a particular tube type are not included in this presentation but are covered by the Handbook data sheets for the given type.

RATINGS

Refer to the *General Section* of the Handbook for a detailed discussion on Rating Systems and Tube Ratings.

CLEANING

As with other high-voltage equipment, it is essential that external parts of power tubes be kept free from accumulated dirt and moisture to minimize surface leakage and the possibility of arc-over.

Some tube configurations contain re-entrant areas at the edge of the insulator seals. Particular care should be taken to prevent foreign matter from coming in contact with these areas. Unless adequately protected by filtered air, these areas collect dirt rapidly as a result of electrostatic forces and the nature of the air circulation around the tube.

The external parts of the tube should periodically be wiped free of dirt. A recommended procedure for cleaning ceramic-metal tubes is as follows:

1. Remove silicone grease or similar material by use of acetone, or equivalent.

   Caution: Do not allow silicone grease or similar materials to remain on any rf contact surfaces. Severe burning of the contact surfaces of cylindrical-terminal types will occur if the contact fingers do not mate firmly with clean metal contact surfaces.

2. Clean rf contact surfaces with a very fine grade of silicon carbide abrasive pad, or equivalent.

   Caution: Do not permit the cleaning pad to come in contact with the ceramic surfaces. Rub gently to prevent removal of plating.

COOLING CONSIDERATIONS

Tube life can always be extended by maintaining envelope temperatures substantially below the maximum temperature ratings.

The user is cautioned that typical cooling characteristics in the published data are offered only as a guide, and that maximum envelope temperatures in the intended operation are the final rating criteria.

Temperature measurements of the tube envelope must be made to insure operation within maximum ratings. For glass-bulb types, the bulb "hot-spot" must be located with the tube operating in its intended application. A simple technique for locating the "hot-spot" in low-power, receiving-type tubes is to apply a low-temperature-melting paint, such as Tempilaq[a], to the entire bulb surface; the point at which this material first begins to melt is the hottest point on the bulb. For most power tubes, however, this technique is not satisfactory because of radiation effects. Therefore, it is recommended that a thermocouple be moved over the envelope to locate the hottest point on the bulb. (Although the individual thermocouple readings are not precise, the relative readings are sufficient.) Spots of various higher temperature Tempilaq paints may then be applied only to the hottest area; the lowest Tempilaq paint which will not melt must be at or below the maximum temperature rating. See Ref. 1. In general, the hottest point of a ring terminal is at the seal or

junction of the terminal and its adjacent glass or ceramic insulator. For some tube types the temperature measurement points are specified on the *Dimensional Outline* in the published data.

All types of heat transfer—radiation, convection, conduction, and combinations thereof—are employed in the various cooling techniques: natural, forced-air, liquid, and conduction cooling.

Natural Cooling—This method is generally used for glass-bulb types having plate dissipation ratings up to about 300 watts.

Temperature should be measured at the hottest point on the bulb using techniques previously discussed.

Adequate free space around the tube is required for all natural cooled types. Avoid reflective heat surfaces such as tube shields. These and other design considerations affecting natural methods of cooling are described in Ref.2.

Forced-Air Cooling—

Glass-Bulb-Types—Forced-air cooling may be applied to glass-bulb types to enhance the convection cooling and reduce bulb temperature. In some glass-bulb types, ratings are given for both natural and forced-air cooling. (The ratings with forced-air cooling reflect the higher permitted value of dissipation.) In general, any natural-cooled type may require some forced-air cooling if operation is near the maximum ratings or if limited space is available around the tube. The final decision can be made only after temperature measurements are made to insure operation below the maximum temperature rating.

Radiator Types—The external plate construction lends itself to compactness, higher

frequency operation, increased power capability and intense-cooling techniques. Because the plate is part of the envelope, transfer of heat by radiation from the plate to the envelope is eliminated. The simplest intense-cooling technique is forced-air. All RCA forced-air-cooled, external-plate types contain integral radiators, which are brazed, pressed, or otherwise secured to the plate to insure intimate thermal contact.

Most of the heat within an electron tube is generated at the plate; additional heat generated from the other electrodes migrates to the plate. Precaution, however, must be taken to insure that none of the other terminals exceed their maximum rated temperature value. It may be necessary to direct some forced air across these terminals.

In general, there are two basic types of radiators: the stacked-disc type of finned radiator for TRANSVERSE FORCED-AIR COOLING, and the radial-fin type of radiator for AXIAL FORCED-AIR COOLING.

Transverse Cooling—Air flow is directed across the radiator from an orifice in a plane normal to the major axis of the tube and at the center of the radiator. More efficient cooling may be accomplished by providing a cowling to direct and confine the air. Pressure drop across the radiator itself is normally insignificant. Typical cooling characteristics for transverse cooling, such as shown in Fig. 1, are given in the published data. The following steps illustrate the use of the chart:

1. Estimate probable *Plate Dissipation* from electrical conditions, locate as point "A" on the abscissa axis (80 watts in example), and erect a perpendicular line "ac".
2. Determine temperature rise by subtracting estimated incoming-air temperature (assume 36°C in example) from estimated



FIG. 1 - EXAMPLE OF TYPICAL COOLING CHARACTERISTICS

tube operating temperature (assume 200°C in example), locate the determined value (200°C-36°C = 164°C in example) as point "B" on the ordinate axis, and construct horizontal line "bc".

3. Determine air flow by interpolating the air flow curves at the intersection of lines "ac" and "bc", point "C" (16 cfm in example).

Axial Cooling—Air flow is directed through the radiator by suitable ducts. Air flow may be in either direction unless otherwise specified. Typical cooling characteristics for axial cooling, such as shown in Fig. 2, are given in the published data. The following steps illustrate the use of the chart:

1. Select a tube operating temperature as discussed in this section, locate as point "A" on the abscissa (assume 200°C in example), erect perpendicular line "ab", extend this line until it crosses the estimated plate dissipation curve (240 watts in example) for temperature (solid line), and designate as point "B".
2. Determine air flow by constructing a horizontal line "bc" from point "B" to the ordinate axis and designate point "C" (3.5 cfm in example).
3. Determine the pressure drop across the radiator for the air flow in (2), locate point "D" on line "bc" at the estimated plate dissipation curve (240 watts in example) for pressure drop (dashed line), construct a perpendicular line "de" to the abscissa axis, designate as point "E", and read pressure drop (0.24 inch of water in the example).

See Ref. 3 for detailed information on the blower requirements for forced-air-cooled tubes.



FIG. 2 - EXAMPLE OF TYPICAL COOLING CHARACTERISTICS

Liquid Cooling—The liquid-cooling system consists, in general, of a source of cooling liquid, a feed-pipe system which carries the liquid to the water jacket surrounding, and provision for interlocking with the power supplies the liquid flow through the cooling courses. A more sophisticated system would also contain a liquid regeneration loop, flow regulators, and gages. For more detailed information on liquid-cooling systems, see Refs. 4 and 5.

Proper functioning of the coolant system is of the utmost importance. Even a momentary failure of the liquid flow may damage the tube. Without coolant the heat of the filament or heater alone may be sufficient to cause serious harm to some tube types. It is necessary, therefore, to provide a method of preventing tube operation in case the coolant supply should fail. A suitable method is the use of coolant-flow interlocks which open the power supplies when the flow is insufficient or ceases. If there is an interruption of the power supplies, it is then necessary to return the filament or heater voltage to zero and to restart in the normal manner described in the published data. The coolant flow must start before application of any voltage and continue for several seconds after removal of all voltages.

The absolute minimum coolant flow required through the system is given in the published data. Under no circumstances should the temperature of the coolant at any outlet ever exceed the maximum value given in the published data.

When the coolant fluid is water and the tube is used in equipment under conditions such that the ambient temperature is below 0 °C, precautions should be taken to prevent the water from freezing in the system.

Use of Water as Coolant—For availability and ease in handling, water is recommended as the coolant wherever possible. It is of utmost importance to maintain a high quality of water in the cooling system. Contamination in the water will hasten scale formation, corrosion, and excessive electrolysis; any one of these conditions can greatly reduce tube life.

Use of Liquids other than Water as Coolant—When ambient temperatures fall below 0°C, it is possible to use coolants such as ethylene-glycol-water solution and FC75b. Neither of these two coolants is as effective a coolant as water, therefore, the plate dissipation and flow data must be modified from that given for water. A more extensive discussion of ethylene-glycol-water solution and FC75 as coolants is given in Ref. 4. For information on the use of any coolant for which ratings are not given in the data, contact your RCA field representative or the nearest District Sales Office. A coolant such as oil will require a special plating on the metal of the tube envelope, such as nickel and rhodium to protect the metal surfaces from chemical attack.

Conduction Cooling—The conduction-cooling system consists, in general, of a constant temperature device (heat sink) and suitable heat-flow path (coupling) between the heat sink and tube. Primary consideration of the system should be given to the design of a heat-flow path (coupling device) with high thermal conductivity.

Heat Sink—The heat sink should be designed to act as a constant-temperature device to prevent any increase in temperature by dissipating the heat beyond the equipment compartment. Heat sinks can take the form of solids or liquids. In most applications such a heat sink is available in the form of equipment chassis, plate line, or output cavity.

Coupling—There are numerous insulating materials available to serve as the heat-coupling device, such as beryllium oxide (beryllia)[C], high-aluminum oxide (high-alumina), mica, and other insulating bodies. Since the thermal conductivity of these insulators varies considerably, the choice of insulator will depend primarily on the plate dissipation in the given application. For a detailed discussion on conduction cooling, see Ref. 6.

In hf operation the inductive element of the plate circuit is usually a relatively long coil, which does not provide a good thermal path from plate to chassis. Larger shunt capacity can be tolerated, however, and heat can be conducted through a portion of it to the chassis. In uhf operation the permissible shunt capacity of the plate circuit is limited, but the inductive element is short and can usually be made with sufficient cross-sectional area to form an excellent thermal path. In vhf operation a careful compromise of the above is required to obtain adequate rf performance and reasonable cooling.

PRECAUTIONS

The voltages at which power tubes are operated are extremely dangerous. Protection circuits must be provided which will protect operation and maintenance personnel, protect the tube in the event of abnormal circuit operation, and protect the tube circuits in the event of abnormal tube operation. Power tubes require mechanical protective devices such as interlocks, relays, and circuit breakers. Circuit breakers alone may not provide adequate protection in certain high-power-tube circuits when the power-supply filter, modulator, or pulse-forming network stores considerable energy. Additional protection may be provided by the use of high-speed electronic circuits

or electronic "crow-bars" to bypass the fault current until mechanical circuit breakers are opened.

Great care should be taken during the adjustment of circuits. The tube and its associated apparatus, especially all parts which may be at high potential above ground, should be housed in a protective enclosure. The protective housing should be designed with interlocks so that personnel cannot possibly come in contact with any high-potential point in the electrical system. The interlock devices should function to break the primary circuit of the high-voltage supplies and discharge high-voltage capacitors when any gate or door on the protective housing is opened, and should prevent the closing of this primary circuit until the door is again locked.

ELECTRICAL CONSIDERATIONS

Cathode—RCA transmitting tubes use a wide variety of cathodes. All utilize thermionic emission and should be operated at a constant temperature.

Refer to the *General Section* of the Handbook for a detailed discussion on TYPES OF CATHODES AND THEIR USE.

Filament or Heater—The rated filament or heater voltage should be applied for the heating time specified in the published data to allow the cathode to reach normal operating temperature before voltages are applied to other electrodes.

The life of the cathode can be conserved by adjusting to the lowest filament or heater supply voltage that will give the desired performance. In general, the filament or heater voltage values given in the published data include the maximum value and the typical value. Exceeding the maximum value will damage or severely shorten the life of the cathode.

The filament or heater voltage should be adjusted to the typical value initially, then reduced to provide satisfactory tube performance; any further reduction will show some degradation.

Good regulation of the filament or heater voltage about the value found above is, in general, economically advantageous from the view-point of tube life. When the rated value is shown with a percentage value in the published data, the percentage value indicates the tolerable momentary fluctuations from the rated value. For longer life, especially at higher operating frequencies, these fluctuations should be reduced by improved power supply regulation.

The cathode may be subjected to back bombardment as the frequency is increased with resultant increase in temperature. In pulse types back bombardment normally need not be considered when the duty factor is small. However, higher duty factors increase the possibility of this effect. In any event, the filament or heater supply voltage should be reduced as described above.

Standby Operation—During standby periods, the tube may be operated at decreased filament or heater voltage to conserve life. It is recommended that the filament or heater voltage be reduced to no less than 80 per cent of normal during standby periods of up to 2 hours. For longer periods, the filament or heater voltage should be turned off.

Filament Overvoltage Pulse Circuits—In certain battery-operated equipment, such as emergency-type, remote-area, or mobile applications, it is of utmost importance to conserve battery power. Quick-heating RCA power tubes provide useful power outputs within about one second from a cold start. This fast "warm-up" feature eliminates the need for standby filament

power, resulting in significant conservation of battery power.

In general, "warm-ups" of about one second are adequate in equipment where the microphone switch actuating the transmitter power relay is located in the cradle of the handset, such as a conventional telephone, or similar wall-type installation. However, when the switch is the push-button type located on the handset, faster "warm-ups" are demanded. Extremely fast "warm-ups" of less than 200 milliseconds are possible for such "push-to-talk" microphone switches by the use of a suitably designed filament overvoltage pulse circuit or "hot-shot" circuit.

The diagram shown in Fig.3 depicts the filament-voltage waveform during a transmission using a "hot-shot" circuit. An overvoltage



FIG.3 - FILAMENT VOLTAGE WAVE FORM

Ef_1 is applied for time t_1. A transfer switch then reduces the filament voltage to the rated value, Ef_2, for the remainder of transmission time t_2. During standby time t_3, the filament voltage is zero.

The block diagram shown in Fig.4 depicts the basic requirements of a "hot-shot" circuit in conjunction with the communication equipment. The auxiliary circuit must provide a low-impedance filament overvoltage source, a rated filament voltage source, an accurately timed means of switching these sources, and a

protective circuit to prevent possible damage to the tube filament from repeated applications of overvoltage with insufficient time for the filament to cool between transmissions. Both filament voltages are obtained from the transmitter power supply. Power is supplied simultaneously to the transmitter and timer



FIG.4 - BASIC RECEIVER-TRANSMITTER WITH AUXILIARY "HOT-SHOT" CIRCUIT

by the **"push-to-talk"** microphone switch. The **transfer switch**, which is initially connected to the **filament overvoltage** source, is switched by the **timer** to the **rated filament voltage** source in the required time (pulse duration) after application of power to the transmitter.

Before a "hot-shot" circuit can be designed for a quick-heating tube, it is necessary to establish maximum ratings for the peak voltage (on the order of 2 to 3 times the rated filament voltage) and duration of the filament overvoltage pulse for the desired heating time. Filament overvoltage pulse ratings are given in the published data on quick-heating tube types.

Any "hot-shot" circuit design must provide protection against the application of the filament overvoltage pulse to a hot filament.

It is recommended that a dummy filament, simulating the resistance of the specific tube type, be used in the initial testing or checking of a "hot-shot" circuit design. Otherwise, any fault—especially an excessive pulse duration can cause catastrophic failure of the tube.

Plate Voltage Supply—Power-amplifier tubes usually obtain plate voltage from rectifiers provided with suitable filter circuits, although batteries or local dc generators are sometimes used, especially in portable and mobile equipment.

A time-delay relay should be provided in the plate-supply circuit to delay application of plate voltage until the filament or heater has reached normal operating temperature.

An interlocking relay system should be provided to prevent application of plate voltage prior to the application of sufficient bias voltage and/or rf drive to grid No.1; otherwise, with insufficient bias, the resultant high plate current may cause excessive plate dissipation with consequent damage to the tube. RF-load shorts or other causes of high output VSWR may also cause high dissipations, excessive voltage gradients, or insulator flashovers. The VSWR should be monitored and the detected signal used to actuate the interlock system to remove the plate voltage in less than 10 milliseconds after the fault occurs.

In beam power tubes with closely spaced electrodes, extremely high-voltage gradients occur even with moderate tube operating voltages. Consequently, momentary fault currents may cause catastrophic failure unless protection is provided. A series impedance in the plate lead is recommended. A resultant plate impedance, which will provide a plate-

voltage-supply regulation of no better thar 10 per cent, is usually sufficient.

Grid-No.2 Voltage Supply—The grid No.2 must be protected by a time-delay and interlocking relay similar to the plate-voltage-supply protection described for Plate Voltage Supply. The plate voltage should be applied simultaneously with or before the grid-No.2 voltage; otherwise, with voltage on grid No.2 only, grid-No.2 current may be large enough to cause excessive grid-No.2 dissipation. If the grid-No.2 voltage is obtained from the plate voltage supply, these precautions will have been accomplished.

Grid-No.2 current is composed of a positive-current component resulting from cathode emission to grid No.2 and a negative-current component resulting from secondary-emission phenomena. Because the net result of these component currents is read on a meter in the grid-No.2 circuit, grid-No.2 dissipation can not be accurately determined. Operation similar to conditions given under *Typical Operation* in the published data will minimize the possibility of exceeding maximum dissipation.

In tubes with precision-aligned grids, such as Cermolox tubes, the grid-No.2 circuit must be capable of maintaining the proper grid-No.2 voltage in the presence of moderate negative dc current as well as normal values of positive current. Complete protection can be achieved by the use of a well-regulated power supply, a grid-No.2-to-ground impedance that is low enough to prevent gradual build-up of grid-No.2 voltage and/or catastrophic build-up (runaway) under negative-current conditions, and a current-overload relay to protect the grid No.2 against positive or negative currents on the order of one-tenth the required plate current.

Grid-No.1 Voltage Supply—The grid-No.1 bias circuit should preferably be adjustable to permit small variations of grid-No.1 voltage. This bias adjustment will permit setting the desired plate current, and it will minimize variations in tube performance. Sufficient fixed bias or cathode resistor bias should be provided to protect the tube in the event that the drive signal is lost.

The design of the bias-voltage supply should include an instantaneous over-current relay. The action of the over-current relay and the inherent regulation of the supply should be such that no damage to the tube or supply will result from an accidental short at the tube connection or from an internal tube fault.

The rf-power-input transmission line should be provided with VSWR protection to remove drive power as well as plate (and grid No.2) voltage within 10 milliseconds in the event of abnormal changes in input VSWR during operation.

CLASSES OF SERVICE

AF Power Amplifiers—The current and power values in the Maximum Ratings are averaged over any audio-frequency cycle of sine-wave form. The driver stage should be capable of supplying at low distortion the No.1 grid(s) with the value of peak af voltage given in the *Typical Operation* of the published data. In no case should the Grid-No.1-Circuit Resistance exceed the value specified under *Maximum Circuit Values*. Transformer or impedance coupling devices are recommended.

Individual bias adjustment for each tube (unit) should be used to balance the loading and minimize distortion. In push-pull operation the bias of each tube (unit) should be adjusted to divide the value of zero-signal plate current in the published data equally between the two tubes (units).

Except for class A amplifiers, the average plate and grid No.2 currents vary with the amplitude of the driving signal. Hence, serious distortion and inadequate power output will result with large input signals unless the plate and grid-No.2 power supplies are well regulated.

Class A—This class normally does not draw grid-No.1 current or requires tube driving power and can employ simple cathode bias. Where class A_2 (indicating grid-No.1 current flows during part of the cycle) is specified, the grid-No.1 circuit precautions discussed under class AB_2 operation will apply.

Class AB_1—The subscript 1 in class AB_1 indicates that grid-No.1 current does not flow during any part of the cycle.

Class B and Class AB_2—These classes normally draw grid-No.1 current (indicated by the subscript 2 in AB_2) with large signals and, therefore, require tube driving power. To minimize distortion, the grid-No.1 bias supply preferably should be regulated or held to a low value of effective resistance. Transformer coupling should be used.

RF Power Amplifiers or Oscillators—On modern ceramic-metal envelope types, the frequency selected is usually the maximum value at which reasonable gain and efficiency are obtained. In glass-envelope types, the maximum frequency is selected as the frequency above which excessive rf envelope losses require voltage deratings and reduced efficiency requires input deratings.

Driving power values given in the published data include only the power that must be delivered to the tube and bias supply. The term, "driving power", is normally used only at low frequencies where circuit losses are small.

Where *Driver-Power Output* is shown in the ıblished data, the rf losses associated with a typical input circuit are also included.

In cathode-drive circuits, a portion of the driver-power output and the developed rf power output act in series to supply the load circuit. Tf the driving power is increased, the output ill always increase. In a grid-drive circuit, a saturation effect takes place; i.e., above a certain value of driving voltage and current, the output increases very slowly and may even decrease. It is important to recognize this difference and not try to saturate a cathode-rive stage; otherwise, the maximum grid-No.1 and grid-No.2 input may easily be exceeded.

Parasitic oscillations may be experienced under certain operating conditions. Such oscillations result in erratic performance and may cause damage to the tube and/or associated circuitry. Operating conditions and external circuits should be adjusted for operation without oscillations. References 10 and 11 are suggested for further information on the detection and suppression of parasitic oscillations.

Class C Plate-Modulated-Power Amplifiers— In plate-modulated class C amplifier service, he tube can be modulated 100 per cent. The rid-No.2 voltage must be modulated simultaneously with the plate voltage so that the ratio of grid-No.2 voltage to plate voltage remains constant.

Grid-No.2 voltage should be obtained pre-erably from a separate source modulated from a separate winding on the modulation transformer.

Bias voltage may be obtained from a grid-No.1 resistor, but preferably is obtained from a combination of grid-No.1 resistor with either ixed supply or cathode resistor to protect the tube in the event the drive signal is lost.

In cathode-drive, plate-modulated, class C rf power amplifier service, the tube can be modulated 100 per cent if the rf driver stage is simultaneously modulated 100 per cent. Care should be taken to insure that the driver-modulation and amplifier-modulation voltages are exactly in phase.

Class C CW Power Amplifiers—In class C rf telegraphy service, the tube may generally be supplied with bias by any convenient method: from fixed supply, by grid-No.1 resistor, by cathode resistor, or by combination methods. However, when the tube is used in the final amplifier or a preceding stage of a transmitter designed for break-in operation and oscillator keying, an amount of fixed bias must be used to limit the plate current and, therefore, the plate dissipation to a safe value. Some fixed bias is preferred in any event to protect the tube in case the drive signal is lost.

Grid-No.2 voltage should be obtained preferably from a separate source. It can also be obtained from the plate-supply voltage with a voltage divider, or through a series resistor. A series grid-No.2 resistor should be used only when the tube is used in a circuit which is not keyed.

Linear RF Power Amplifiers—The classes of operation suitable for linear rf power amplifiers include: class A, class AB_1, class AB_2, class B with bias, and class B with zero bias. Class A operation is the more nearly linear, but it is also the least efficient. Application is generally limited to low-power-level amplification. Class AB_1 produces the best compromise for linearity, efficiency, and gain. Class AB_2 or class B operation provides higher output for applications where sufficient driving power is available to permit some "swamping", and where linearity requirements are less stringent. Class B zero-bias operation

with suitable high mu triodes may be used when adequate driving power is available.

In general, grid-No.2 voltage should be obtained from a separate, well-regulated source. In circuits where the grid-No.1 current is drawn, a separate, well-regulated source is also required.

(1) - **Single-Sideband, Suppressed Carrier Service**—Single sideband suppressed carrier operation is a form of linear amplifier service in which only one sideband is transmitted, and the carrier is suppressed.

The values of *Distortion Products Level* given under *Typical Operation* in the published data are referenced to either of the two tones for "two-tone" modulation and are without the use of feedback to enhance linearity.

(2) - **Class B and Class C Television Service**—Television is a form of linear amplifier service in which the rf carrier is modulated by a video signal. Typical operation is given at conditions of a specified bandwidth measured between the half-power points.

The values for the pertinent parameters given under *Typical Operation* in the published data are given at the synchronizing (sync) level and pedestal level (black level or blanking level).

(3) - **Class B Telephony Service**—Class B telephony service is a form of linear amplifier service in which the grid is excited with an rf carrier that is modulated at audio frequencies in one of the preceding stages. Under these conditions, plate dissipation is greatest when the carrier is unmodulated. Grid bias should be obtained from a dc voltage source of good regulation.

Pulsed RF Amplifiers and Oscillators—This service consists of the generation and amplification of an rf signal, the envelope of which is a waveform limited to intermittent

pulses of defined shape, duration, and repetition frequency. Pulse duration and duty factor are sometimes limited directly by the maximum ratings. More frequently, the maximum ratings define a relationship between these factors as a maximum "ON" time in a given time interval in order to cover pulse-train inputs. Typical operation, in general, is given for conditions with a rectangular waveshape pulse of a given duration and duty factor. For operation at pulse durations or duty factors other than those given in the published data, see Ref.12.

In the amplifier service, the power supply pulses should preferably start shortly after and end shortly before the rf drive pulse to reduce the possibility of parasitic oscillations. If the rf drive pulses are "gated" within the power-supply pulses (the rf drive pulse starts shortly after and ends shortly before the power-supply pulses), the desired "gate" conditions should be observed carefully when no rf drive pulse is present to be assured that no oscillations are present.

The peak input energy required during the pulse is normally obtained from capacitor banks that must store many times this peak value to prevent excessive voltage droop. Consequently, it is particularly important to observe all the precautions for limiting tube input during faults which are described under Grid-No.2 Voltage Supply.

Pulse-Modulated RF Amplifiers—This service consists of the simultaneous amplification and pulse modulation of a cw rf signal. If differs from the other more conventional modulated rf amplifier services in that the modulating waveform is limited to intermittent pulses of defined shape, duration, and repetition frequency. This type of amplification/modulation is normally done at low power levels; hence, few power tubes are rated specifically for this service.

Pulse Modulator Service—The tube supplies a modulation signal consisting of intermittent pulses of defined shape, duration, and repetition frequency. Ratings, waveforms, and precautions are similar to those given for pulsed rf amplifier service (except there is no rf drive signal).

Observation of the exact waveforms must be made with an oscilloscope. In this manner, transient voltage or current spikes caused by unavoidable circuit reactances may be observed. Transient values must be held within the maximum ratings given in the published data.

High-power pulse modulators, when used to "clip" or "flat-top" the output waveform by the overdriving technique, must provide grid-No.1 and grid-No.2 input protection.

Plate current flow during the "OFF" time will contribute to plate dissipation; the bias voltage should be sufficient to hold the plate current below the required levels for any tube. The control limits, such as found in the Characteristics Range Values will provide information in determining the required bias. Current flow during the rise time and the fall time of a "rectangular" pulse can contribute significantly to plate dissipation; this current flow should be considered if the theoretical plate dissipation is close to the rated value.

Voltage Regulator Service—The tube acts as a "pass tube" having a controllable voltage drop in a series-regulated voltage-supply circuit. The plate voltage rating can be interpreted as applying to the actual plate-to-cathode voltage of the tube rather than the supply voltage. In this case, adequate protective devices must be used to protect the tube in the event of a shorted load. Special precaution should be made to observe the maximum circuit values for grid-No.1 and grid-No.2 impedance. For information on voltage regulator circuits, see Refs. 13,14, and 15.

It is recommended that only tube types rated for this service be used since the use of a high power vacuum tube in a high-voltage, low-current application will frequently result in the selection of a tube inadequately controlled in the low-current region.

[a] Made by the Tempil Corp., 132 W. 22nd Street, New York 1, New York.

[b] Manufactured by the Fluorchemical Division, Minnesota Mining and Manufacturing Co., 900 Bush Avenue, St. Paul 6, Minnesota.

[c] **Warning: Beryllia dust and fumes are highly toxic to mucous membranes and may cause serious ulcers when imbedded under the skin. See References 7, 8, and 9.**

REFERENCES

Copies for references 1, 3, 4, and 6 may be obtained by writing to Commercial Engineering, Radio Corporation of America, Harrison, New Jersey.

1. *Techniques for Measuring Electron-Tube Bulb Temperatures, RCA Application Note, AN-200.*

2. *Design Manual of Natural Methods of Cooling Electronic Equipment,* Department of the Navy, Bureau of Ships, Navships 900, 192.

3. *Blower Requirements for RCA Forced-Air-Cooled Tubes,* RCA Application Note, AN-161.

4. *Application Guide for RCA Super-Power Tubes,* 1CE-279A.

5. *Design Manual of Methods of Liquid Cooling Electronic Equipment,* Department of the Navy, Bureau of Ships, Navships 900, 195.

6. J. W. Gaylord, *"The Conduction Cooling of Power Tubes in Vehicular Communication Equipment,"* IEEE Transactions on Vehicular Communications, September, 1963.

Cont'd

7. D. W. White, Jr. and J. E. Burke, *"The Metal Beryllium"* (book), published by the American Society for Metals, Cleveland, Ohio.

8. Donald P. O'Neil, *"Toxic Materials Machined Safely,"* American Machinist, June 4. 1955.

9. Sidney Laskin, Robert A. N. Turner, and Herbert E. Stokinger, *"Analysis of Dust and Fume Hazards in a Beryllium Plant,"* U.S. Atomic Energy Commission, MDDC-1355.

10. F. E. Terman, *"Radio Engineers' Handbook,"* pages 498 to 503 of 1943 edition. Published by McGraw-Hill Pub. Co., Inc.

11. EE Staff of MIT, *"Applied Electronics,"* page 619.

12. *Predicted Cathode Capability,* RCA Power Tube Engineering Note, IEN-1.

13. F. V. Hunt, & R. W. Hickman, Review of Scientific Instruments, *"On Electronic Voltage Stabilizers,"* January, 1939.

14. F. E. Terman, *"Radio Engineers' Handbook,"* pages 614 and 615 of 1943 edition. Published by McGraw-Hill Pub. Co., Inc.

15. Cruft Electronics Staff, *"Electronic Circuits and Tubes,"* page 575. Published by McGraw-Hill Pub. Co., Inc.